

INTERIOR ROOM / SPACE INFO	
NAME	FLOOR AREA(m2)
BATHROOM	5.43
BED 1	13.03
HALL	2.93
L'DRY	0.85
LIVING ROOM	17.23
	39.47 m²

Ceiling insulation needs to be upgraded to R6.0 to comply with EER.

Walls insulation needs to be upgraded to R2.5 to comply with EER.

CANBERRA GRANNY FLAT BUILDERS